

PANVEL MUNICIPAL CORPORATION





Office No- 27458040/41/42 Fire Office No- 27461500 Email-Panvelcorporation@gmail.com Fax No- 022-27452233

Outword/No/Pmc/Fire/2121/Ref. No.1447/2862/

Date- 06 /06 /2024

APPENDIX - VII

FIRE SAFETY CERTIFICATE

Certified that the M/S. DAV PUBLIC SCHOOL at Plot No. 267/268, Sector-10, New Panvel, Navi Mumbai comprised of Ground + 5rd Upper Floor (3 Wings) owned / occupied by M/S. DAV PUBLIC SCHOOL have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officer concerned of Fire Service on 03/07/2024 in the presence of Principal Mr. Sumanth Ghosh / M/s. United Sales Corporation, Fire License Agency and that the building/premises is fit for occupancy up to Class XII with effect from 03/07/2024 for a period of 1 Year in accordance with rule and subject to compliance of specific conditions as appended:-

- 1) In build Fire Fighting System Should be kept in good working condition all the time.
- 2) As per the Maharashtra Fire Prevention & Life Safety Act, 2006 it is statutory requirement to check the in-built fire protection system from licensing agency twice in a year (in the month of July & December) & produce the Form 'B' certificate to this department
- 3) School management shall trained all staff members to operate the Fire Extinguisher.

Issued on 03/07/2024 at Navi Mumbai by

Signature with Seal:

Name

: Pravin B. Bodkhe

Designation

: Chief Fire Officer

Name & Address of Department / Office: Panvel Municipal Corporation

To,

Principal,

M/S. DAV PUBLIC SCHOOL

Sector-10, New Panvel, Navi Mumbai