



ANALYSIS REPORT

Name of the customer & add. : DAV Public School.
Plot No.267, Sector 9-10,
New Panvel, Navi Mumbai,
Maharashtra - 410206

Kind Attn. : Mr. Anil Thakur.

Name of sample with relevant details : Terrace Tank Water-2

Quantity (gm or ml) : 1000 ml.

Sample received in : In Plastic Bottle.

Sample condition : Liquid in tightly stoppered bottle.

Environmental Condition while Testing: Ambient Temperature: 25°C & Humidity: 52%

Sample as submitted by customer

Test Report No.: AE/26-27/2764
Report Date: 21/09/2026
Sample Ref. No.: 2764
Dt. of sample Recd.: 16/09/2026
Period of analysis:
From: 16/09/2026 to 21/09/2026
ULR No. : TC1775026000003561F

Parameters	Results	Units	Drinking Water Standards As Per IS 10500:2012	Methods
Chemical:				
pH @ 25°C	7.40	-	6.5-8.5	IS:3025 (Part-11)
Turbidity	2.3	NTU	Max 1.0	IS:3025 (Part-10)
Conductivity @ 25°C	193.7	µS/cm	Not Specified	IS:3025 (Part-14)
Total Dissolved Solids	114.0	mg/L	Max 500.0	IS:3025 (Part-16)
Total Hardness (as CaCO ₃)	63.60	mg/L	Max 200.0	IS:3025 (Part-21)
Calcium (as Ca)	16.11	mg/L	Max 75.0	IS:3025 (Part-40)
Magnesium (as Mg)	5.60	mg/L	Max 30.0	IS:3025 (Part-46)
Total Alkalinity (as CaCO ₃)	51.22	mg/L	Max 200.0	IS:3025 (Part-23)
Chloride (as Cl)	16.46	mg/L	Max 250.0	IS:3025 (Part-32)
Sulphate (as SO ₄)	14.68	mg/L	Max 200.0	IS:3025 (Part-24)
Iron (as Fe)	<0.1	mg/L	Max 1.0	IS:3025 (Part-53)

- Notes :**
- 1) Results relate to the sample tested without prejudice to its lot, source or process.
 - 2) Test report shall not be reproduced except in full without written approval of the Laboratory In charge.
 - 3) Any query related to this report will be entertained within 8 days of the report date only and the sample will be also retained for the same period.
 - 4) Our analytical findings reflect the quality of the sample at the time of testing only.
 - 5) Our liability if any arising out of the use of this test report is limited to the testing charges paid by you for testing this sample.

Reviewed By

P.S. Dixit
Authorized Signatory

.....End of the report.....

Page 1 of 1



ANALYSIS REPORT

Name of the customer & add. : DAV Public School.
Plot No.267, Sector 9-10,
New Panvel, Navi Mumbai,
Maharashtra – 410206
Kind Attn. : Mr.Anil Thakur.
Name of sample with : Terrace Tank Water-2
relevant details
Quantity (gm or ml) : 1000 ml.
Sample received in : In Plastic Bottle.
Sample condition : Liquid in tightly stoppered bottle.
Environmental Condition while Testing: Ambient Temperature: 25°C & Humidity: 52%
Sample as submitted by customer.

Test Report No.: AE/26-27/467
Report Date: 21/09/2026
Sample Ref. No.: 467
Dt. of sample Recd.: 16/09/2026
Period of analysis:
From: 16/09/2026 to 21/09/2026


Parameters	Results	Drinking Water Standards
------------	---------	--------------------------

Microbiological:

Coliform	Absent	Absent
E. coli	Absent	Absent

- Notes : 1) Results relate to the sample tested without prejudice to its lot, source or process.
2) Test report shall not be reproduced except in full without written approval of the Laboratory In charge.
3) Our analytical findings reflect the quality of the sample at the time of testing only.
4) Our liability if any arising out of the use of this test report is limited to the testing charges paid by you for testing this sample.

Reviewed By 


P.S. Dixit
Authorized Signatory

.....End of the report.....